

- 59 DFA
C-60



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS : DELHI FIRE SERVICE : NEW DELHI – 110001

No.F6/DFS/MS/GH/NDZ/ 836

Dated: 22./11./2021

To,

The Manager,
M/S Prince Palace Dx, Guest House,
3519, Dariba Pan, Pahar Ganj, New Delhi.

Sub: Issuance of FSC (Fire Safety Certificate) in r/o M/S Prince Palace Dx, Guest House,
3519, Dariba Pan, Pahar Ganj, New Delhi. ID NO. 2021082218538 dated 10.09.21.

Sir,

This has reference to on line ID No. 2021082218538 dated 10.09.21 on the subject cited above. In this regard, it is to inform you that the site was inspected by the officers concerned of this department on 12/11/2021 in the presence of Mr. Juber and following shortcomings were observed: -

1. Smoke management system not provided as per gazette notification dated 27.05.2019.
2. CO type detectors are not provided as per gazette notification dated 27.05.2019.
3. Fire extinguishers are due for refilling.
4. Hose reel is not provided at each floor.

Hence, Fire Safety Certificate (FSC) cannot be issued at this stage due to above shortcomings. Therefore, you are requested to rectify the above shortcomings and re-submit for further consideration in the matter.

Yours faithfully,



(Dr. S.K. Tomar)
Dy. Chief Fire Officer
Delhi Fire Service

Copy to

1. The Addl. Commissioner of Police (Lic), First Floor, P.S. Defence Colony, New Delhi.
- 