

C-47

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS : DELHI FIRE SERVICE : NEW DELHI - 110001

Dated: 22/11/2021

No.F6/DFS/MS/GH/NDZ/ 825

To,

The Manager
M/S Raj Guest house,
P. No 3849, Tel Mandi,
Pahar Ganj, New Delhi.

**Sub: Issuance of FSC (Fire Safety Certificate) in r/o M/S Raj Guest House plot no 3849,
Tel Mandi, Pahar Ganj, New Delhi ID No. 2021092622566 dated 26.09.21.**

Sir,

This has reference to on line ID no 2021092622566 dated 26.09.21 on the subject cited above. In this regard, it is to inform you that the site was inspected by the officers concerned of this department on 12/11/2021 in the presence of Mr. Raj and following shortcomings were observed: -

1. Smoke management system is not provided as per Gazette Notification dated 27.05.2019.
2. An undertaking not to use any floor above third floor is not submitted.
3. The building plan as uploaded is not signed by owner itself.

Hence, Fire Safety Certificate (FSC) cannot be issued at this stage due to above shortcomings. Therefore, you are requested to rectify the above shortcomings and re-submit for further consideration in the matter.

Yours faithfully,


18/11/21

(Dr. S.K. Tomar)
Dy. Chief Fire Officer
Delhi Fire Service

Copy to:

1. Addl. Commissioner of Police(lic) , Ist floor , Defence Colony Police Station, New Delhi