

C-68

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEAD QUARTERS : DELHI FIRE SERVICE : NEW DELHI – 110001**

No.F6/DFS/MS/GH/NDZ/ 2021/837

Dated: 22/11/2021

To,

The Manager,  
M/S Ravina Palace Guest House,  
962, Gali Kumaharan,  
Pahar Ganj, New Delhi.

**Sub: Issuance of FSC (Fire Safety Certificate) in r/o M/S Ravina Palace Guest House, 962, Gali Kumaharan, New Delhi ID No. 2021100923815 dated 09.10.21.**

Sir,

This has reference to on line ID No. 2021100923815 dated 09.10.21 on the subject cited above. In this regard, it is to inform you that the site was inspected by the officers concerned of this department on 12/11/2021 in the presence of Mr. Sahanavaz and following shortcomings were observed: -

1. CO type detectors are not provided as per gazette notification dated 27.05.2019.
2. The building plan as uploaded, rooms are shown whereas in application form no guest room is mentioned. The same be clarified.

Hence, Fire Safety Certificate (FSC) cannot be issued at this stage due to above shortcomings. Therefore, you are requested to rectify the above shortcomings and re-submit for further consideration in the matter.

Yours faithfully,

  
12/11/21

(Dr. S.K. Tomar)  
Dy. Chief Fire Officer  
Delhi Fire Service

Copy to

1. The Addl. Commissioner of Police (Lic), First Floor, P.S. Defence Colony, New Delhi.