

CB

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CANNAUGHT PLACE
NEW DELHI- 110 001**

No. F6/DFS/MS/Restaurant/2021/NDZI/ 527

Dated: 22/11/21

To,

Rise food and Beverages Nazeer,
E- 985, Ground Floor 100 Feet Road ,
Babarpur , Delhi-110094

Sub:- Regarding Issuance of Fire Safety Certificate in r/o Rise food and Beverages Nazeer
E- 985, Ground Floor 100 Feet Road , Babarpur , Delhi-110094.

Sir,

With reference to your online application No. 2021091721729 dated 22/09/2021 on the subject cited above. In this connection, it is to inform you that the officer concerned of this department has carried out the inspection of the above mentioned restaurant from fire safety point of view in presence of Mr. Alam (Manager). During the course of inspection the following shortcomings were observed.

1. Exit door of 02 & 1.50 meters wide is not provided.
2. Down-comer is not provided.
3. A fire pump having 450 lpm output of 40 meters head at terrace is not provided.

In view of above, the building can not be considered for issuance of Fire Safety Certificate at this stage. Therefore you are suggested to rectify the above mentioned shortcomings under the intimation to this department for further course of action.

Yours faithfully


(Atul Garg)
Director

Copy to:-

1. The Joint Commissioner (Lic.)
1st floor Police Station Defence Colony,
New Delhi
2. The Commissioner (EDMC)
Plot No 419, Patparganj Industrial Area,
Delhi-110092