

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS : DELHI FIRE SERVICE : NEW DELHI – 110001**

No.F6/DFS/MS/School/2021/ 62

Dated: 17 /02/2021

To

The Principal,
R.M. Arya Girls Sr. Sec. School
Behind Madhya Pradesh
Emporium, Baba Kharak Singh Marg,
Raja Bazar, New Delhi

**Sub: Regarding issuing of FSC in r/o R.M. Arya Girls Sr. Sec. School at Behind
Madhya Pradesh Emporium, Baba Kharak Singh Marg, Raja Bazar, New Delhi**
Sir,

This has reference to your E-mail < raghumalaryagirlsschool@yahoo.co.in > dated 21.01.2021 on the subject cited above. In this regard, it is to inform you that the site was inspected by officer concerned of this department on 03.02.2021 in the presence of Smt. Preeti Mehata and the following shortcomings were observed.

1. Fire extinguishers are due for refilling.
2. Hose reel found nonfunctional.
3. Terrace pump found nonfunctional
4. Exit Signages are found inadequate.

In view of above shortcomings, fire safety certificate (FSC) cannot be renewed.

Yours faithfully


10/2/21

(Dr. S.K. Tomar)
Dy. Chief Fire Officer
Delhi Fire Service



Copy to:-

The Director (Education),
Govt. of NCT, Old Sectt.
Delhi - 54.