

(82)

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS : DELHI FIRE SERVICE : NEW DELHI – 110001

No.F6/DFS/MS/GH/NDZ/ 834

Dated: 22/11/2021

To,

The Manager,
M/S Venus Deluxe Guest House,
Plot No. 3423 Gali Hari Mandir,
Pahar Ganj, New Delhi.

Sub: Issuance of FSC (Fire Safety Certificate) in r/o M/S Venus Dx. Guest House, Plot No. 3423 Gali Hari Mandir, Pahar Ganj, New Delhi ID No. 2021082118525 dated 22.09.21.

Sir,

This has reference to on-line ID No. 2021082118525 dated 22.09.21 on the subject cited above. In this regard, it is to inform you that the site was inspected by the officers concerned of this department on 12/11/2021 in the presence of Mr. Gopal and following shortcomings were observed: -

1. Smoke management system is not provided as per gazette notification dated 27.05.2019.
2. CO type detectors are not provided as per gazette notification dated 27.05.2019.
3. The overhead fire water tank of capacity 2000 liter provided against the requirements of 2500 liter.

Hence, Fire Safety Certificate (FSC) cannot be issued at this stage due to above shortcomings. Therefore, you are requested to rectify the above shortcomings and re-submit for further consideration in the matter.

Yours faithfully,


12/11/21

(Dr. S.K. Tomar)
Dy. Chief Fire Officer
Delhi Fire Service

Copy to

The Addl. Commissioner of Police (Lic), First Floor, P.S. Defence Colony, New Delhi.