

c62

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI – 110001

No. F6/DFS/MS/GH/NDZ/2021/ 844

Dated: 25/11/2021

To

The Joint Commissioner of Police (Licensing),
1st Floor, Police Station Defence Colony,
New Delhi.

Sub: Regarding renewal of Fire Safety Certificate in respect of **Zam Zam Guest House 939, 952, Gali Shyam Lal, Matiya Mahal, Delhi.**

Sir,

With reference to online application no. 2021101424197 dated 14.10.2021 on the subject cited above, it is informed that the said guest house had been issued Fire Safety Certificate vide letter no. F6/DFS/MS/GH/NDZ/2020/04 dated 03.01.2020 which was valid for a period of three years from the date of issue subject to compliance of fire safety provisions as required in Gazette Notification dated 27.05.2019. The Guest House was re-inspected by Assistant Divisional Officer (SPM) from this department on 16.11.2021 in the presence Mr. Moham Rajik (staff) and following shortcomings were observed during inspection:-

1. No provisions for Smoke Management were found provided in the common areas of 2nd & 3rd floor.
2. CO detectors with panel and hooter not provided as required in Gazette Notification dated 27.05.2019.
3. Plastic feeder pipe to hose reel to be replaced by GI pipe.
4. Auto starting of fire pump not provided.
5. The plan uploaded with the online application was not matching the actual site.

In view of above shortcomings, the revalidation of Fire Safety Certificate issued vide letter no. F6/DFS/MS/GH/NDZ/2020/04 dated 03.01.2020 cannot be considered at this stage. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier. The Authority/Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,


22/11/21

((Dr. S.K. Tomar))

Dy. Chief Fire Officer

Tel: 011-23412025

9/c Qh
18/11

Copy to:-

The Licensee,

Zam Zam Guest House 939,952,Gali Shyam Lal, Matiya Mahal, Delhi.