

C-38

5

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS : DELHI FIRE SERVICE : NEW DELHI – 110001

No.F6/DFS/MS/School/NDZ/2021/ 619

Dated: 30 /11/2021

To

The Principal,
M/s Ahlcon Public School,
Mayur Vihar, Phase-I, Delhi – 110091.

Sub: Regarding Fire Safety Certificate in r/o M/s Ahlcon Public School located at Mayur Vihar, Phase-I, Delhi – 110091.

Sir,

This has reference to your letter no. AIS/Fire Safety/2021-22 dated 20/09/2021 on the subject cited above. In this regard, it is to inform you that the premises was inspected by the officer concerned of this department on 08/11/2021 in the presence of Mr. Sanjay Yadav (Principal) & Mr. Vikram and observed that earlier school was Basement + Ground + 03 upper floors but now the school building is comprised of Basement + Ground + 03 upper floors + terrace floor (Atal Lab). Therefore this is a case of additional/alteration and needs to route your application through bldg. deptt. of East MCD.

Hence, renewal of Fire Safety Certificate can not be considered at this stage.

Yours faithfully

(Atal Garg)
Director

Delhi Fire Service

Copy to:-

1. The Dy. Director of Education,
D-Block, Anand Vihar, Delhi.
2. The Commissioner East MCD,
419, Udyog Sadan, Patparganj Industrial Area,
Patparganj, New Delhi, Delhi 110096.