

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS, DELHI FIRE SERVICE, NEW DELHI-110001**

No. F6/DFS/MS/EH/MN/2021/889

Dated: 30/11/2021

e-98

To,

The Joint Commissioner of Police (Lic.)  
1<sup>st</sup> Floor, P.S. Defiance Colony  
New Delhi -110063.

**Subject: - Inspection report in respect of M/s. Aman Dx, Guest House, A - 31, Vishal, Enclave, Rajouri Garden New Delhi-110026.**

Sir,

Please refer to your online application through MHA portal vide I.D. No. 2021080116497 dated 07/08/2021 on the subject cited above. In this connection, it is to inform you that the said building was inspected by the officer concerned of this department on 23/11/2021 in presence of Sh. Vijay Dhama to check the shortcomings already issued by this department vide letter no. F6/DFS/MS/GH/2021/WZ/487 dated 29.07.2021.

The Status of the Shortcomings are as under.

S. no.	Shortcomings	Status
1.	Smoke management system provided but not working..	Not Rectified
2.	First Aid Hose reels are provided but not working.	Rectified
3.	MOEFA is provided but not working.	Not Rectified
4.	Automatic sprinkler system is provided in Basement but not working.	Rectified
5.	Terrace pump is found removed.	Rectified
6.	Overhead water storage tank found removed.	Not Rectified
7.	Exit signage's are found removed.	Not Rectified
8.	Use of third floor as guest room shall be closed.	Rectified ( Sealed by Owner/Occupier)
9.	Fire check door's found removed.	Not Rectified
10.	Carbon Mono-Oxide detectors are not provided.	Not Rectified

In view of above Shortcomings the application for Issuance of Fire safety Certificate is rejected. The occupancy of the Building/ premises in absence of requisites fire safety Arrangements Shall be at the risk and liabilities of the Owner/occupier. The licensing issuing authority/statutorily authority is requested that premises should not be allowed to run till it provide all necessary fire arrangements.

Yours Faithfully

(Dharampal Bhardwaj)  
Dy. Chief Fire Officer  
West Zone

Copy To : -

1. The Owner/Occupier M/s. Aman Dx, Guest House, A- 31,Vishal, Enclave, Rajouri Garden New Delhi-110026.
2. The Dy. Health Officer, West Zone, Shivaji Enclave, Rajouri Garden, New Delhi-110027. (dhowest [zone@gmail.com](mailto:zone@gmail.com))

C-89

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS, DELHI FIRE SERVICE, NEW DELHI – 110001**

No. F.6/DFS/MS/GH/2021/WZ/487

Dated 29/07/2021

To,

The Joint Commissioner of Police (Lic.)  
1<sup>st</sup> Floor, P.S. Defiance Colony  
New Delhi –110063.

**Sub:--**Inspection report in respect of M/s. Aman Dx, Guest House, A-31, Vishal, Enclave, Rajouri Garden New Delhi-110026.

Sir,


Please refer to your Online Application ID. No. 2021032211515 dated 23/032021 on the subject cited above. In this connection, it is to inform you that the said premises was inspected by the officer concerned of this department on 05/07/2021 in the presence of Sh. Akhilesh to check to check the Fire safety arrangements.

During inspection, It was observed that the building is comprised of Basement +Ground+03 Upper Floors, Guest House is running at first Floor & second floor (07 Guest rooms each floor). Fire safety arrangements such as Fire Extinguishers Hose Reel, MOEFA, down comer, Exit Signage etc. found provided. However, following shortcomings were observed:-

1. Smoke management system provided but not working..
2. First Aid Hose reels are provided but not working.
3. MOEFA is provided but not working.
4. Automatic sprinkler system is provided in Basement but not working.
5. Terrace pump is found removed.
6. Overhead water storage tank found removed.
7. Exit signage's are found removed.
8. Use of third floor as guest room shall be closed.
9. Fire check door's found removed.
10. Carbon Mono-Oxide detectors are not provided.

In view of above shortcomings, the application for Renewal Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier. The licensing Authority/Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,

  
(Dharampal Bhardwaj)  
Dy. Chief Fire Officer  
Delhi fire Service  
West Zone

Copy to: - Sh. Akhilesh, M/s Aman Dx, Guest House, A-31, Vishal, Enclave, Rajouri Garden New Delhi-110026

o/c  
26/7/2021