


C-23

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI – 110001

No. F.6/DFS/MS/NDZ/2021/ 555

Dated: 7.12.2021

The Deputy Commissioner (Licensing)
1st Floor, Police Station Defence Colony,
New Delhi.

Subject:- Online Application ID No.- **2021101224054** in r/o **Coffee Home** situated at Plot no. 14,
District Centre, Laxmi Nagar, Delhi-110092.

Sir,

This has a reference to online application ID No.- **2021101224054** dated 22.10.2021 received on the subject cited above. In this connection, it is to inform you that premises was inspected by the officer concerned of this department on 12.11.2021 in the presence of Mr. Manoj Gupta (Manager) and observed that restaurant/ banquet hall heaving following shortcomings at site.

1. Ventilation system not functional in basement.
2. Hose reel not provided in basement & 1st floor hall.
3. MCP found removed.
4. Hydrant not provided in basement & 1st floor hall.
5. Fire pump not on auto mode.
6. Overhead water tank capacity of 5,000 liters provided against required capacity of 7,500 liters not provided.
7. Offices & wine shop running in basement.
8. MS Iron staircase passing through kitchen area (photo enclosed).
9. Electrical panel installed in basement staircase creating hazards (photo enclosed).

In addition to above the application needs correction in respect of number numbers of staircase, width of staircase, width of door. Accordingly, the applicant may be directed to furnish correct information and compliance of above shortcomings for further necessary action for issuance of Fire Safety Certificate.

Hence the application is rejected.

Yours faithfully,


(Atul Garg)
Director

Delhi Fire Service

Copy to:-

Mr. Pramod Kumar Gupta,
Coffee Home Plot no. 14, District Centre, Laxmi Nagar, Delhi-110092.

