



65

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001**

NO. F-6/DFS/MS/ 2021/ 06

Dated 7/12/2021

To

The Manager  
Lotus Banquet (P R S Events), Plot No-7259,  
Prem Nagar Shakti Nagar, Delhi-110007.

**Sub:** - Regarding issuance of fire safety certificate in r/o M/s Lotus Banquet (P R S Events), Plot No-7259, Prem Nagar Shakti Nagar, Delhi-110007.

Sir,

This has reference to your online I. D. No. 2021100823724 dated 12.10.2021 on the subject cited above. In this connection this is to inform you that the above mentioned site was visited by the officer concerned of this department on 17.11.2021 in the presence of Mr. Harsh Sharma (Manager) to verify the fire safety arrangements as stipulated in NBC Part 4 and as well installed in the building. During the course of inspection it has observed that the building/ premise is comprised of ground & 02 upper floors (Banquet Hall is ruining at Ground & First floor only). Your request for FSC is rejected under Rule 35 (3) due to following shortcomings.

- 1 Fire check door not provided in the Building.
- 2 Smoke ventilation system is not provided at all floors.
- 3 Hose reel hose provided but not functional and crack/damaged condition.
- 4 MOEFA System not provided.
- 5 Public address system is not provided.
- 6 Internal hydrants provided but not functional. and hose boxes are in damaged condition.
- 7 Terrace level firefighting pump capacity of 900lpm is not provided.
- 8 Terrace level fire water tank capacity of 25,000ltrs not provided.
- 9 Exit signage's not provided at strategic location in the banquet hall.

Keeping in view of above Fire Safety Certificate cannot be considered at this stage. You may apply again on form 'I' as stipulated in sub rule (2) 35 of rules, DFS Rules 2010 after compliance of the shortcoming mention above. The link for forms is as under available on <http://delhi.gov.in./wps/wcm/connect/doit fire/FIRE/Home/Forms>.

Yours faithfully

  
(Anil Garg)  
Director  
Ph: 011-23414000

gpc 4

Copy to :

1. The Dy. Commissioner, (Civil Line Zone) North Delhi Municipal Corporation, 16, Rajpura Road, New Delhi-110054.