

C25



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001

No. F.6/DFS/MS/SZ/EH/2021/ 554

Dated: 7/12/2021

To
The Dy. Health Officer,
South Zone, SDMC, Green Park,
Aurobindo Marg, New Delhi

Sub: Issue of Fire Safety Certificate in r/o Ms Radio Station (A Unit of Foodholic Factory Pvt. Ltd) at HS-6, 2nd Floor, Kailash Colony Market, New Delhi

Sir,

This is in reference to with MHA Portal ID 2021102825397 dated 16-11-2021, received in this department on the subject cited above. The premise was inspected by the concern nominated authority of this department in presence of Mr. Parkash (Manager) on dated 30-11-2021 & observed that the building is comprised of Ground + Mezz.+Three upper floor. During the course of inspection, the following shortcoming observed were noticed:-

1. There are two staircases having width of 2.0 mtr & 1.00 mtr respectively against the required width of 1.50 mtr each.
2. There are two doors having width of 1.60 mtr & 1.00 mtr against the required width of 1.50 mtr each.
3. Hose reel hose provided but not working.
4. Automatic fire detection & alarming system not working.
5. The MOEFA system is not provided.
6. The Internal Hydrant provided but not in working order.
7. Electric Fire Pump capacity 2280 LPM, Diesel Engine Pump 2280 LPM and Jockey Pump 180 LPM are not provided. Terrace level Fire Pump capacity of 450 LPM provided but not in working order.
8. Overhead tank capacity 10,000 ltrs provided against the requirement of 20,000 ltrs. Underground water storage tank for fire fighting having capacity 1, 00,000 ltrs not provided as per NBC Part IV.
9. Exit signage not provided.
10. Standby power supply not provided.

In view of above Shortcomings, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier. The Licensing authority/ Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,


(Atul Garg)
Director


Copy to: -

1. Ms Radio Station (A Unit of Foodholic Factory Pvt. Ltd) at HS-6, 2nd Floor, Kailash Colony Market, New Delhi