

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEAD QUARTERS : DELHI FIRE SERVICE : NEW DELHI – 110001**

No.F6/DFS/MS/CH/NDZ/ 2021 290

Dated:- 05/02/2021

To,

The Dy. Commissioner of Police (Lic.)  
First floor, PS Defence Colony  
New Delhi.

**Sub: Issuance of FSC (Fire Safety Certificate) in r/o Civil Services Officers Institute (CSOI) at K. G. Marg, New Delhi ID No. 2020102708060 dated 27.10.2020**

Sir,

This has reference to on line ID No. **2020102708060 dated 27.10.2020** on the subject cited above. In this regard, it is to inform you that the site was inspected by the officers concerned of this department on 02/02/2021 in the presence of Mr. Viresh Rawat and following shortcomings were observed: -

1. First aid hose reel found nonfunctional.
2. Hydrant system found nonfunctional.
3. Exit signages found inadequate.

Hence, Fire Safety Certificate (FSC) cannot be issued at this stage due to above shortcomings. Therefore, you are requested to direct the applicant to rectify the above shortcomings and re-submit for further consideration in the matter.

Yours faithfully,



(Dr. S.K. Tomar )  
Dy. Chief Fire Officer  
Delhi Fire Service



**Copy to :-**

The Manager,  
**Civil Services Officers Institute (CSOI) at K. G. Marg, New Delhi.**