

C-34

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

No. F6/DFS/MS/2021/SZ/ 954

Dated: 7/12/2021

To
Authorized Signatory,
The Icon, D-823, New Friends Colony,
New Delhi-110065.

Sub.:- Fire Safety Certificate in r/o The Icon, D-823, New Friends Colony, New Delhi-65.

Sir,

With reference to your MHA Portal App. No.-2021101424184 dated 16/10/2021 on the subject noted above, in this connection it is to inform you that the said building premises was inspected by the officer concerned of this department on 18.11.2021 in the presence of Sh. Vivek Chandna (Owner).

During the course of inspection it was observed that the building premises is comprised of Basement, Ground Floor & Three Upper Floors only and observations ~~are~~^{as} as per under:-

1. Fire check doors not provided.
2. Detector of Carbon Mono oxide type (CO) not provided.

In view of above shortcomings, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building / premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner / occupier. The Licensing Authority / Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,



(SUNIL CHAWDHARY)
DY. CHIEF FIRE OFFICER (S.Z.).

Copy to :-

1. The Addl. Commissioner of Police (Lic.), 1st Floor Police Station, Defence Colony,
New Delhi-110049.