

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CANNAUGHT PLACE
NEW DELHI- 110 001**

No. F6/DFS/MS/School/2021/NDZ/ 630

Dated: 07/12/2021

The Principal
M/s DAV Public School,
East of Loni Road
Delhi110093

Sub:- Regarding issuance Fire Safety Certificate in r/o M/s DAV Public School at East of Loni Road, Delhi-110093.

Sir,

This is in reference to your letter No. nil dated 08/11/2021 on the subject cited above. In this connection, it is to inform you that the officer concern of this department has carried out the inspection of the above mentioned school from fire safety point of view on 25/11/2021 in presence of Mrs. Sameeksha Sharma, Principal of the School. During inspection it was observed that this department has issued Fire Safety Certificate to the school for Ground plus two upper floors only vide letter No.F-6/DFS/MS/School/2015/NDZ/1991 dated 04/11/2015. The following points / shortcomings were observed.

1. Fire Extinguisher's provided but not functional at the time of Inspection.
2. First-Aid Hose reel provided but not functional at the time of Inspection.
3. A fire pump having 450 LPM output at 40 meters head is provided but not functional.
4. Over Head water tank 10,000 liters capacity provided but empty at the time of inspection.

In view of above, the building can not be considered for issuance of Fire Safety Certificate at this stage. Therefore you are suggested to rectify the above mentioned shortcomings under the intimation to this department for further course of action.

Yours faithfully

(Signature)
4/12/21

**(Dr.S.K.Tomar)
Dy.Chief Fire Officer**

(Signature)

Copy:-

The Dy. Director of Education
B-Block, Yamuna Vihar,
Delhi110053