

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001**

No. F.6/DFS/MS/School/2021/NDZ/647

Dated: 13/12/2021

To,

The Principal,
EDMC Primary School,
Buland Masjid, Shastri Park Extension
Delhi-110053

Subject:- Request for site visit.

Sir,

With reference to letter No. E.E. (Elect.)-II/Shah (S)/2021-2022/D-570 dated 27/10/2021 on the subject cited above, it is informed that officer concerned of this department inspected the school from fire safety point of view in presence of Sh. Manoj Kumar Aggarwal, Principal of the school & Sh. Kuldeep Kumar Singh, J.E. (Elect.) Shahdara South Zone on dated 29/11/2021. The school building comprises of ground plus two upper floors. During the course of inspection following observations was made:-

1. One staircase of width 1.50 meter or an additional staircase of 0.75 meter width is not provided.

In view of the above, the school building cannot be considered for issuance of Fire Safety Certificate at this stage. Therefore, you are requested to provide the above mentioned fire safety arrangements under intimation to this office for further course of action.

Yours faithfully,

(A. N. Garg)
Director

Copy to:-

1. The Director of Education, EDMC
Udyog Sadan, Plot No. 419, FIE,
Patparganj Industrial Area, Delhi-110092
2. The Ex. Engr. (Elect.)-II/SSZ
EDMC, Office of Executive Engineer (Elect.)-II/SSZ,
2nd Floor Technical Laboratory,
Near NH-24 Gazipur, Delhi-110096