

c-36

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

No: F.6/DFS/MS/School/2021/WZ/ 650

Dated: 13/12/2021

To,
The Principal,
Govt. Co-ed Sr. Sec. School,
Bhorgarh, Delhi-110040.

Sub: - Regarding renewal of Fire Safety Certificate in r/o Govt. Co-ed Sr. Sec. School, Bhorgarh, Delhi-110040.


Sir,

This has reference to your e mail id dated 25.11.2021 on the subject cited above. In this connection, it is to inform you that the inspection of above said school building has been carried out by officer concerned of Fire Service on 02.12.2021 to see the compliance of the requisite fire safety measures. Sh. Harinder Kumar (H.O.S.) was present at the time of inspection. During the course of inspection it was observed that school building comprised of ground floor plus three upper floors and was issued FSC by this department vide letter no.F6/DFS/MS/School/2018/2644 dated 07.12.2018. Your request of renewal of FSC is rejected as the following shortcomings were observed:-

1. Hose reel nozzle found missing.
2. Hose boxes found broken and hose couplings found missing.
3. Internal Hydrant valves were choked.
4. Terrace level pump found not functional.

You are advised to rectify the above-mentioned shortcomings for taking further action as necessary for renewal of Fire Safety Certificate.

Yours Faithfully,


(Dharampal Bhardwaj)
Dy. Chief Fire Officer
West Zone

Copy to:-

1. Director of Education, Govt. of NCT of Delhi, Old Secretariat, New Delhi – 110054