

C-336

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS : DELHI FIRE SERVICE : NEW DELHI – 110001

No.F6/DFS/MS/2021/965

Dated.10./12./2021

To,

The Manager,
Hotel Marina, G-59, Connaught Circus, New Delhi- 110001.

Sub: Regarding renewal of fire NOC in r/o M/s Hotel Marina, G-59, Connaught Circus,
New Delhi.

Sir,

With reference to your online ID No. 2021102224896 dated 26.10.21 (Hotel Marina), ID No. 2021111226189 dated 13.11.21 (Restaurant -The Great Kabab Factory) and ID no. 2021112327002 dated 02.12.21 (FIFTY 9) on the subject cited above. In this connection it is to inform you that the site was inspected by the officers concerned department on 06.12.21 in the presence of Sh. Neeraj Kumar, Fire Officer and the following shortcomings were observed:-

1. Hydrant and hose reel are not covering entire area of hotel, need to be extended in kitchen side area. Further, one hydrant & hose reel is also required to be provided at terrace level.
2. Detectors found nonfunctional at some places.
3. MOEFA found nonfunctional.
4. Height of building is mentioned 15 meter whereas all building plans are not uploaded on portal. Accordingly, building plans of all floors including section/elevation showing occupancy details at each floor with duly signed by the architect and owner is required to be uploaded on the portal.

Therefore, you are requested to rectify the above shortcomings and re-submit for further consideration in the matter

Yours faithfully,


21/12/21

(Dr. S.K.Tomar)
Dy. Chief Fire Officer
Ph. 011- 23412025

Copy to:-

The Joint Commissioner of Police
Licensing Unit,
Defence Colony Police Station,
New Delhi.

