

298

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001

NO. F6/DFS/MS/GH/2021/SZ/ 978

Dated 13/ 12/2021

To

The Joint Commissioner of Police / Lic.
1st floor, Police Station
Defence Colony, New Delhi 110049

Sub: - Regarding issuance of fire safety certificate in r/o M/s Jasmine Boutique (A Unit of Amazon Buildcon Private Limited) located at Plot No-50, Pocket-1, Jasola Vihar, New Delhi-110025


Sir,

This has reference to with MHA Portal ID 2021041212763 dated 17-04-2021 on the subject cited above. In this connection this is to inform you that the above mentioned premise was visited by the officer concerned of this department to verify the fire safety arrangements as stipulated in NBC Part-IV and as well installed in the building. Accordingly fire safety arrangement were tested / checked and found following observation.

- 1 Fire check doors not provided at first floor as per clause 7.31 of UBBL 2016.
- 2 Carbon Monoxide detector not provided as per clause 7.31 of UBBL 2016.
- 3 Fire pumps are not on auto mode.

In view of above Shortcomings, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier. The Licensing authority/ Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully



(SUNIL CHAWDHARY)
DY. CHIEF FIRE OFFICER



Copy to:

1. M/s Jasmine Boutique (A Unit of Amazon Buildcon Private Limited) located at Plot No-50, Pocket-1, Jasola Vihar, New Delhi-110025 .