

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

Dated: 10/12/2021

No. F6/DFS/MS/2021/WZ/ 566
 To,

Mr. Sachin Kohli,
 House No.220, New Modern Apartment,
 Plot No.26 2, Sector-9, Rohini,
 New Delhi-110085.

Sub: Issue of FSC in r/o M/s Karim s a unit of Muscle Masters Foods, Shop No.101,101,103,121 & 122, First Floor, Crescent Square Mall, Plot No.14, DC Chowk, Sector-09,Rohini, Delhi - 110085.

Sir,

This is in reference to your online application No. 2021082922898 dated 04.10.2021 on the subject cited above. The premise was inspected by the concern nominated authority of this department on **22.10.2021**, in presence of **Sh. Yogesh (Manager)** to ascertain the availability and operability of the fire prevention and fire safety measures. The following shortcomings were observed:

1. The width alternate staircase is 1.4m against the required width of 1.5 mtr.
2. Fire check door are not provided.
3. Fire protection system provided is not functional.
4. Overhead water tank & terrace pump are not accessible.
5. MOEFA is not provided.
6. The FSC for main occupancy (Basement + Ground + 02 upper floors) mercantile building is required as restaurant being contingent upon main occupancy.

You are advised to apply with a fresh application for grant of fire safety certificate after rectifying above shortcoming for further considered in this matter.

Yours faithfully

(Atul Garg)

DIRECTOR

Ph; 011-23414000

Copy to:

1. Mr. Yogesh (Manager), M/s Karim s a unit of Muscle Masters Foods, Shop No.101,101,103,121 & 122, First Floor, Crescent Square Mall, Plot No.14, DC Chowk, Sector-09,Rohini, Delhi -110085.