

21/11/21
C-70

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI- 110001

No. F.6/DFS/MS/GH/2021/SZ/ 984

Dated: 10/11/2021

To

The Addl. Commissioner of Police (Lic.),
1st Floor, P.S. Defence Colony,
New Delhi-110049.

Sub: Issuance of NOC in r/o M/s Private Affair Hospitality, C-2, Greater Kailash Part- 1, New Delhi 110048.

Sir,

This is in reference with MHA Portal ID 2021072916208 Dated 21/09/2021 on the subject cited above. In this connection, the premises have been inspected by officer concerned of this department on 26/11/2021 in the presence of Mr. Anuj Kumar of the Guest House. During the inspection, it was observed that the Guest House is running in Basement, Stilt, Ground plus Three Upper Floors. During the course of inspection, the following shortcoming observed were noticed:-

1. Fire check door not provided in the building as per clause 7.31 of UBBL-2016.
2. Carbon Monoxide detector not provided as per clause 7.31 of UBBL-2016.

In view of above Shortcomings, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier. The Licensing authority/ Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,



(SUNIL CHAWDHARY)
DY. CHIEF FIRE OFFICER (SZ)

ont

Copy to:-

1. Mr. Kailash Chandra Soni (Prop) M/s Private Affair Hospitality, C-2, Greater Kailash Part- 1, New Delhi 110048