

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE: CANNAUGHT PLACE  
NEW DELHI- 110001

No.F6/DFS/MS/School/SZ/648

Dated: 13/12/2021

To,

The Principal,  
S.D.M.C Pratibha Vidyalaya,  
Site-IV, Vikaspuri, New Delhi-110018.

**Sub:** -Regarding issue of "Fire Safety Certificate" from fire safety point of view in r/o S.D.M.C  
Pratibha Vidyalaya, Site-IV, Vikaspuri, New Delhi-110018.


Madam,

Please refer to your letter Nil Dated 15/11/2021 on the subject cited above. In this connection this is to inform you that officer concerned of this department inspected the school to verify the fire safety arrangements in accordance with the rules. At the time of inspection Smt. Priya Arora (In-Charge) was present and it was observed that the school building is comprised of ground plus two upper floors and have following shortcomings:-

1. Fire extinguishers provided but not functional.
2. First Aid Hose reels provided but not functional.
3. Fire pump having 450 LPM output at 40 m head provided but not functional.
4. Over head water storage tank found damaged.

In view of above, the fire safety certificate cannot be considered at this stage. You are requested to rectify the above shortcoming under the intimation to this department for further course of action.

Yours faithfully



(Sunil Chawdhary)  
Dy. Chief Fire Officer  
Delhi Fire Service

Copy to:-

The Director of Education,  
S.D.M.C, Civic Centre,  
Minto Road, New Delhi-110001.

