GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI - 110001

No. F6/DFS/MS/GH/NDZ/2021/ 986

Dated: 13/12/2021

To

The Joint Commissioner of Police (Licensing), 1st Floor, Police Station Defence Colony, New Delhi.

Regarding renewal of Fire Safety Certificate in respect of M/S Shree BalaJi Inn Guest House, located at 11, 1262, Nalwa Katra Baryan, Fatehpuri, Delhi.

Sir,

With reference to Online application no. 2021032511644 dated 20.11.2021 on the subject cited above, it is informed that the guest house was inspected by Assistant Divisional Officer (SPM) from this department on 06.12.2021 in the presence Mr. Kishan Pandey, manager and it was observed that building is comprised of Ground + 03 upper floors. During inspection, following shortcomings were observed:-

- 1. Fire check door not provided as per required Gazette Notification dated 27.05.2019.
- 2. First aid hose reels found non functional and provided at ground floor only, it should be provided at every floor.
- 3. CO detectors with panel and alarm not provided in the guest house as required in Gazette Notification dated 27.05.2019.
- 4. P.A. System found non functional.
- 5. Fire pump having capacity 225 LPM and head 30 mtrs found non functional.
- 6. Exit signages not provided.
- 7. The as built floor plan and elevation plan of the building with fire & life safety provisions duly marked on it, signed and stamped by a registered architect and the Licensee/ owner/ occupier has not been uploaded alongwith the online application.

In view of above shortcomings, the application for issuance for Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier. The Authority/Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,

((Dr. S.K. Tomar) Dy. Chief Fire Officer

Tel: 011-23412025

Copy to:-.

The Licensee,

M/S Shree BalaJi Inn Guest House, located at 11, 1262, Nalwa Katra Baryan, Fatehpuri, Delhi.