

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS : DELHI FIRE SERVICE : NEW DELHI – 110001

No.F6/DFS/MS/2021/646

Dated.13.12/2021

To,

The Principal,
Sri Guru Nanak Khalsa Sec. School,
Ahata Kidara, Bara Hindu Rao, Delhi – 06.

Sub: Regarding grant of FSC in r/o Sri Guru Nanak Khalsa Sec. School, Ahata Kidara, Bara Hindu Rao, Delhi - 06 (Gr. + Mezz. + 03 Upper floor).

Sir,

This has a reference to your letter no. SGNK -314/F-88/2021 dated 29/09/2021 & Email < 1208137school@gmail.com > dated 06.10.2021, on the subject cited above. In this regard, it is to inform you that the site was inspected by the officer concerned of this department on 02/12/2021 in the presence of Mrs. Manjit Kaur and observed that shortcomings issued earlier vide letter no. F6/DFS/MS/2018/2127 dated 17.05.18 & letter no. F6/DFS/MS/2021/427 dated 25.08.2021 (copy enclosed) are still not complied.

In view of above, the application for issuance of fire safety certificate is rejected. The occupancy of building /premises, in absence requisite fire & life safety arrangements, shall be at the risk and liability of the owner/occupier. The statutory authority may take suitable action as deemed fit.

Yours faithfully

Encl: As above



(Dr. S.K. Tomar)
Dy. Chief Fire Officer
Delhi Fire Service



Copy to:-

1. The Director (Education), Govt. of NCT, Old Sectt. Delhi.

2/10

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS : DELHI FIRE SERVICE : NEW DELHI - 110001

No.F6/DFS/MS/2018/ 2/27

Dated 17/5/18

To,

The Principal,
Sri Guru Nanak Khalsa Sec. School,
Ahata Kidara, Bara Hindu Rao, Delhi - 06

Sub: Regarding grant of FSC in r/o Sri Guru Nanak Khalsa Sec. School,
Ahata Kidara, Bara Hindu Rao, Delhi - 06 (Gr. + Mezz. + 03 Upper floor).


Sir,

This has reference to your letter No. 75/F-88/18 dated 28/03/2018 on the subject cited above. In this regard, it is to inform you that the site was inspected by the officer concerned of this department on 28/04/2018 in the presence of Mrs. Manjit Kaur (Eng. Teacher) and the following shortcomings were observed:-

1. One additional staircase to be provided.
2. Hose reel not provided.
3. Fire pumps capacity of 450 LPM not provided.
4. Overhead water tank capacity of 10,000 liter not provided.
5. Exit signage not provided.

Hence, FSC cannot be considered at this stage.

Yours faithfully



(Sunil Chowdhary)
Dy. Chief Fire Officer
Delhi Fire Service



Copy to:-

1. The Director (Education),
Govt. of NCT, Old Sectt.
Delhi.