



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE  
NEW DELHI- 110001

C-51

No. F6/DFS/MS/GH/2021/SZ/ 975

Dated: 13/12/2021

To,

The Manager,  
Guest House Surya Plaza,  
1/20, Tilak Nagar, New Delhi-110018.

**Sub:** - Regarding issue of "Fire Safety Certificate" from fire safety point of view in r/o Surya Plaza Guest House, 1/20, Tilak Nagar, New Delhi-110018.

Sir,

This has reference to your application no. 2021102324950 dated 25/10/2021 on the subject captioned above. In this connection, it is to inform you that the above mentioned building/premises was inspected by the officer concerned of this department on 15/11/2021 & 07/12/2021 in the presence of Sh. Shiv Charan Kapoor to verify the compliance of shortcoming already communicated by this department vide letter no. F6/DFS/MS/GH/2020/SZ/1088 dated 01/10/2020 & F6/DFS/MS/GH/2021/SZ/478 dated 27/07/2021 and observed that shortcomings are still not rectified. The management will be held responsible for any untoward incident for the period if compliance is not made. Hence the case for NOC from fire safety point of view is rejected.

Yours faithfully

(Sunil Chawdhary)  
Dy. Chief Fire Officer

Copy to:-

The additional Commissioner of Police,  
Licensing Unit, Office of the Joint Commissioner of Police,  
1<sup>st</sup> Floor, Police Station, Defence Colony, New Delhi.  
(With a request to take further action as guest house does not have fire NOC)

C-39

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI – 110001**

No: F.6/DFS/MS/GH/2020/SZ/ 1088

Dated: 01/10/2020

To,

The Additional Commissioner of Police,  
Licensing Unit, Office of the Joint Commissioner of Police,  
1<sup>st</sup> Floor, Police Station, Defence Colony, New Delhi

Sub: - Regarding the compliance with the Gazette Notification No. F.5(189)AD/LB/2016/4053-67 dated 27.05.2019, letter no. F.5(189)AD/LB/2016/11940-55 dated 25.09.2019 and F.5(189)AD/LB/2016/171-186 dated 27.12.2019 in respect of existing building in r/o Guest House Surya Plaza, 1/20, Tilak Nagar, New Delhi-110018.

Sir,

This has reference to online application ID 20200912172904 on the subject cited above. In this regard it is to inform you that the above mentioned guest house has been inspected by the officer concerned of this department on 24.09.2020 to check the status as per the Notification and letter no. F.5(189)AD/LB/2016/171-186 dated 27.12.2019. Sh. Mukesh Kumar (Front Office) was present at the time of inspection.

During the course of inspection it is observed that the management of the guest house complied with most of the Gazette notification except the carbon monoxide detectors in each room and fire check door in staircases. In addition to this following shortcomings were also observed:-

1. Corridor ventilation not provided.
2. Four fire extinguishers are provided against required six fire extinguishers.
3. Pantry on first floor.
4. Affidavit regarding the partial usage of third floor is to be provided.

Therefore the management of the guest house may be advised to comply with above mentioned shortcomings, till then the Fire Safety Certificate issued vide letter no. F.6/DFS/MS/GH/2017/SZ/259 dated 23.02.2017 cannot be renewed in the interest of public safety till the compliance of above mentioned shortcomings along with Gazette notification requirement dated 27.05.2019.


Yours faithfully,



(S.S. TULI)  
Dy. CHIEF FIRE OFFICER  
SOUTH ZONE

Copy to:-

The Manager,  
Guest House Surya Plaza,  
1/20, Tilak Nagar, New Delhi-110018  
(for compliance of above mentioned shortcomings)

  
29/09/2020