

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI – 110001

No. F6/DFS/MS/School/WZ/2021/649

Dated: 13/12/2021

To,

The Principal,
Govt. Sarvodaya Kanya Vidyalaya No. 2,
Shakurpur, Delhi-110034.

Sub. :-Issuance of Fire Safety Certificate in r/o (New Block) Govt. Sarvodaya Kanya Vidyalaya No. 2 (School ID- 1411030) Located at Shakurpur, Delhi-110034.

Sir,

Please refer to your email dated 03.11.2021 on the subject cited above. In this connection it is to inform you that the said School building has been inspected by the officer concerned of this department on 02.12.2021 in presence of Sh. Imran Ahmad (Contractor, PWD) to check workability/functionability of Fire safety systems provided in the building as per UBBL/NBC Part-IV.

During inspection, the following shortcomings have been observed:-

1. The New Building Block is not accessible for fire tenders as 06 m wide motor able road is not provided.
2. The Main entrance gate is 385 cm wide against requirement of 4.5 m.
3. Fire Pump is provided but not in auto operation.

In view of the above shortcoming, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier. The Education Authority may take suitable necessary action as deemed fit.

Yours faithfully,

(Atul Gang)
Director

Copy to:-

1. The Director, Directorate of Education, Old Secretariat Delhi – 110054.