

65

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS : DELHI FIRE SERVICE : NEW DELHI – 110001

No.F6/DFS/MS/NDZ/2021/

560

Dated:- 7.12/2021

To

The Manager
M/S HANDI CHHADEYAN DI,
Located at Shop no. 59, Municipal Market,
Outer Circle Connaught Circus, New Delhi.

Sub: Regarding issuance of FSC in r/o M/S HANDI CHHADEYAN DI, at located at Shop no. 59, Municipal Market Outer Circle, Connaught Circus, New Delhi.

Sir,

This has reference to online ID No. 20211030255558 dated 30.10.21 on the subject cited above, it is to inform you that the site was inspected by the officers concerned department on 25/11/2021 in the presence of Sh. Santosh and the following shortcomings were observed:-

1. Single staircase of .75 meter is provided against the requirements of 02 staircase of 1.5 meter each.
2. One exit of 1.0 meter is provided at ground floor against the requirements of 02 exit of 1.5 meter each.
3. Fire extinguishers are not provided as per IS 2190.
4. First aid hose reel and hydrant system are not provided.
5. MOEFA is not provided.
6. Terrace pump of 450 LPM & Overhead fire water tank of 20,000 liter cap. are not provided.
7. Exit signages found inadequate.
Further, you have uploaded only section /elevation plans whereas building plans of restaurant having all details duly signed with Architect and Owner itself is also required to be uploaded.

In view of above, Fire Safety Certificate cannot be issued. Therefore, you are requested to rectify the shortcomings for further consideration in the matter.

Yours faithfully


(Atul Garg)
DIRECTOR
Delhi Fire Service

Copy to :-

The Joint Commissioner of Police (Lic.), Licensing Unit, Defence Colony
Police Station, New Delhi.