

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS, DELHI FIRE SERVICE, CONNAUGHT PLACE**

No. F6/DFS/MS/BNQT/WZ/2021/07

Dated: 08/12/2021

C-29

To,

The Rajender Kumar Bharti,  
R.K Banquet Hall,  
7/16 Kirti Nagar Industrial Area,  
New Delhi- 110015

Subject: Regarding Renewal of NOC from fire safety point of view in respect of M/s R.K Banquet Hall Located at 7/16 Kirti Nagar Industrial Area New Delhi- 110015

Sir,

Please refer to your online application no. 2021101223991 dated 14/10/2021 on the subject mentioned above. In this connection, it is to inform you that the premises was inspected by the officer concerned of this department on 26/11/2021 in the presence of Sh. Rajender Kumar Bharti (Owner) to check the functioning of fire safety arrangements provided in the building.

During inspection, it has been observed that the building/premises is comprised of Basement + Stilt + Ground + 01 upper floors was issued FSC (for Ground Floor Only) vide letter no. F6/DFS/MS/2018/WZ/2559 dated 27/11/2018. Fire Safety arrangements such as Fire Extinguishers, First -Aid, Hose reel, Terrace pump, overhead water storage tank etc. have been provided in the building. However, the following shortcomings were observed.

1. Smoke Management system is not functional.
2. MOEFA is not functional.
3. P.A. System is not functional.
4. Overhead tank capacity of 25000 ltrs is provided against requirement of 30,000 ltrs & used for a Domestic purpose.
5. Exit signages are found removed.
6. Terrace floor is used as kitchen in temporary shed & fully covered.
7. Stilt floor is used as office & Kitchen.
8. The Sealing of upper floors by bricks wall is opened.

In view of above Shortcomings the application for Issuance of Fire safety Certificate is rejected. The occupancy of the Building/ premises in absence of requisites fire safety Arrangements Shall be at the risk and liabilities of the Owner/occupier. The license issuing authority/statutorily authority is requested that premises should not be allowed to run till it provide all necessary fire Safety arrangements.

Yours faithfully,

(Dharampal Bhardwaj)  
Dy. Chief Fire Officer  
West Zone

Copy To:-

1. Dy. Health Officer, Karol Bagh Zone, NDMC, Anand Parbat, New Delhi.

08/12/2021  
04/12/2021