

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001**

No. F6/DFS/MS/2021/SZ/ 979

Dated: 10/12/2021

To

Authorized Signatory,  
M/s Amar Inn Guest House, K-102, Jal Vihar  
Road, Lajpat Nagar-II, New Delhi-110024.

**Sub.:- Fire Safety Certificate in r/o M/s Amar Inn Guest House, K-102, Jal Vihar Road,  
Lajpat Nagar-II, New Delhi-110024.**

Sir,

With reference to your MHA Portal App. No.- 2021111726578 dated 17/11/2021 on the subject noted above, in this connection it is to inform you that the said building premises was inspected by the officer concerned of this department on 30/11/2021 in the presence of Smt. Ritu (Manager).

During the course of inspection it was observed that the building premises is comprised of Basement, Ground Floor & Three Upper Floors only and observations are as per under:-

1. Fire check doors not provided.
2. Detector of Carbon Mono oxide type (CO) not provided.

In view of above shortcomings, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building / premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner / occupier. The Licensing Authority / Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,



(SUNIL CHAWDHARY)  
DY. CHIEF FIRE OFFICER (S.Z.).

Copy to :-

1. The Addl. Commissioner of Police (Lic.), 1<sup>st</sup> Floor Police Station, Defence Colony,  
New Delhi-110049.