

c-28

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE
CONNAUGHT PLACE: NEW DELHI-110001

No. F.6/DFS/MS/EH/2021/SZ **573**

Dated: 15/12/2021

To

Mohd. Nadeem Khan,
M/s Gourmet Greens
(A Unit of N. Square Hospitality LLP)
Shop No. 19, 20 & 21, Ground Floor,
Savitri Cinema Complex, DLF Center,
Greater Kailash Part-II, New Delhi-110048


Sub: **Inspection Report in r/o M/s Gourmet Greens (A Unit of N. Square Hospitality LLP),
Shop No. 19, 20 & 21, Ground Floor, Savitri Cinema Complex, DLF Center, Greater
Kailash Part-II, New Delhi-110048**

Sir,

This is in reference to online application No. 2021111926762 dated 19/11/2021. In this connection, it is to inform you that the said premises was visited by officer concerned of this department on 07/12/2021 in the presence of Mr. Satish Kumar to verify the compliance of shortcomings communicated vide this department letter No. F.6/DFS/MS/EH/2021/229 dated 20/05/2021 and observed that the shortcomings except as mentioned at serial no. 2, 5 & 6 have been complied.

In view of above, you are requested to rectify all the left over shortcomings -for further consideration by this department.

Yours Faithfully,


(Atul Garg)
Director

Delhi Fire Service

9c se

Copy to: -

1. The Dy. Health Officer, South MCD, South Zone, Public Health Department, Green Park, New Delhi-110016

clm

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001**

NO. F-6/DFS/MS/EH/2021/ 229

Dated 20/05/2021

To

The Dy. Health Officer,
SDMC, South Zone,
Green Park, Delhi 110016

Sub: - Regarding issuance of fire safety certificate in r/o **M/s Gourmet Greens**, (A Unit of N Square Hospitality LLP) situated at Ground Floor, Shop No 19, 20 & 21 Savitri Cinema Complex DLF Center, Greater Kailash Part -2, Delhi 110048

Sir,

This has reference to your Online ID 2021031211234 dated 30/03/2021 on the subject cited above. In this connection, this is to inform you that the above mentioned premise was visited by the officer concerned of this department on 16.04.2021 in the presence of Sh. Amar Kumar Jha (Manager) to verify the fire safety measures installed in the building and observed that the building is comprised of Basement, ground plus 02 upper floors and restaurant is running at ground floor only. During inspection, following points were observed:

1. There are two door's having width of 1.50 mtr & 1.0 m against the required doors having width of 1.50 mtr each.
2. Fire door for segregation / Compartmentation of kitchen & seating area not provided
3. The MOEFA system is provided but not working.
4. Terrace level Fire Pump capacity 180 LPM provided against the required capacity of 450 LPM.
5. Overhead tank capacity 5,000 ltrs provided against the required capacity of 20,000 ltrs.
6. Inflammable material (Plastic green leaves decorative material) used in wall paneling ceiling level, which is not acceptable as per clause 7.31 of UBBL- 2016

In view of above Shortcomings, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier. The Licensing authority/ Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully


(Atul Garg)
Director


Copy to:

1. Joint C P (Lic.) P.S. Defence Colony, New Delhi 110049 (Ref. online ID 2021031211234 dated 30/03/2021)