

G-11

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

No. F.6/DFS/MS/School/2021/NDZ/ 857

Dated: 16/12/2021

To,

The Principal,
EDMC Primary School,
Jagat Puri (General), Mandoli Road,
Shahdara, Delhi-110093

Subject:- Regarding issuance of Fire Safety Certificate.

Sir,

With reference to your email Id eee2shahnorthzone@gmail.com dated 23/11/2021 on the subject cited above, it is informed that officer concerned of this department inspected the school from fire safety point of view in presence of Ms. Chetna Rani, Incharge & Sh. Gajender Singh J.E. (Elect.), Shahdara North Zone on dated 04/12/2021. The school building comprises of ground plus two upper floors. During the course of inspection following observations was made:-

1. One staircase of width 1.50 meter or an additional staircase of 0.75 meter width is not provided.

In view of the above, the school building cannot be considered for issuance of Fire Safety Certificate at this stage. Therefore, you are requested to provide the above mentioned fire safety arrangements under intimation to this office for further course of action.

Yours faithfully,


(Atul Garg)
Director

Copy to:-

1. The Director of Education, EDMC
Udyog Sadan, Plot No. 419, FIE,
Patparganj Industrial Area, Delhi-110092
2. The Ex. Engr. (Elect.)-II,
Shahdara North Zone,
EDMC, Office of Executive Engineer (Elect.)-II,
MCD Zonal Office Building, Keshav Chowk,
G.T. Road, Near Shyam Lal College,
Delhi-110053