

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE: CANNAUGHT PLACE  
NEW DELHI- 110001

642

No. F.6/DFS/MS/School/2021/SZ/ 656

Dated: 16/12/2021

To,

The Principal,  
Govt. Girls/Boys Sr. Sec. School,  
G- Block, Vikaspuri, New Delhi-110018.

Sub: - Regarding grant of NOC from fire safety point of view in r/o Govt. Girls/Boys Sr. Sec. School, G- Block, Vikaspuri, New Delhi-110018.

Sir/Madam,

This has reference to your letter no. GSKV/GBLK/2021/709 dated 15/11/2021 on the subject captioned above. In this connection, it is to inform you that the premise was inspected on 03/12/2021 by the officer concerned of this department in the presence of Smt. Urmila Devi (Vice-Principal) to verify the compliance of shortcomings already communicated by this department vide letter no. F6/DFS/MS/School/2019/SZ/3531 dated 13/06/2019 & F6/DFS/MS/School/2021/SZ/413 dated 13/08/2021 & F6/DFS/MS/School/2021/SZ/592 Dated 01/11/2021. During the course of inspection it was observed that the shortcomings have not been rectified except point no 3 & 4.

In view of above, the fire safety certificate cannot be considered at this stage. You are requested to rectify the shortcomings under intimation to this department for further course of action.

Yours faithfully

(Sunil Chawdhary)  
Dy. Chief Fire Officer



Copy to:-

1. The Director of Education,  
Govt. of NCT of Delhi,  
Old Secretariat, New Delhi-110054.  
(With a request to take further action as school does not have fire NOC)
2. Assistant Engineer (E),  
Education (Maint.) Sub Division M1-1,  
PWD, ITI Campus, Pusa, New Delhi-110012.

C-21

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001**

No.: F.6/DFS/MS/School/2019/SZ  
To,

Dated: 13/06/19

Assistant Engineer (E),  
Education (Maint) Sub Divn M1-1,  
PWD, ITI Campus, Pusa,  
New Delhi-110012

Sub: - Regarding issuance of Fire Safety Certificate in r/o Govt. Girls/Boys Sr. Sec. School, G-Block, Vikas Puri, New Delhi-110018.

Sir,

This has reference to your Letter No. 54(SPS)SCHOOL/PWD Edu.Maint.DivnM1/2018-19/10 dated 18.03.19 on the subject cited above. In this connection, it is to inform you that the inspection of above said school building has been carried out by officer concerned of this department on 17.05.19 to see the compliance of the requisite fire safety measures. Sh. H.S. Mishra (Estate Manager) was present at the time of inspection.

During the course of inspection it was observed that school building comprised of four blocks namely A-Block, B-Block, C-Block & MP hall block. Block-A, Block-B & Block-c are having ground plus three upper floors & MP hall having ground floor only. The upper floors A block are served by single staircase having width 172 cms and the upper floors of B-Block are served by two staircases having width 172 & 172 cms and the upper floors of Block-C are served by single staircase having width 168 cms. The fire protection arrangements such as Fire Extinguishers, Hose reels, Overhead water storage tank having capacity 10000 ltrs in each block, Fire pumps of 450 LPM (02 no.'s) in each block, Exit signs etc. are provided in the building. The building is approachable to the fire fighting vehicles. The electrical wiring was seen concealed and the electric supply was passing through MCB's. The following shortcomings were observed:-

1. The upper floors of Block-C are served by single staircase having width 168 cms against required two staircases having width 150 & 135 cms each from ground floor to terrace.
2. Door width is 115 cms (double doors) against required 120 cms in C block.
3. Hose reel system provided but not functional in Block-A and Block-B. Nozzles are missing in Block-C.
4. Fire pump having capacity 450 LPM (02 no.'s) provided in Block-A & Block-B but not functional.

You are advised to rectify the above-mentioned shortcomings for taking further action as necessary for grant of Fire Safety Certificate.

Yours Faithfully,

(ATUL GARG)  
CHIEF FIRE OFFICER

Copy to:-

1. Director of Education,  
Govt. of NCT of Delhi, Old Secretariat,  
New Delhi - 110054
2. The Principal,  
Govt. Girls/Boys Sr. Sec. School,  
G-Block, Vikas Puri, New Delhi-18

At c Sam  
10/6/19