

C-70

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI- 110001

No. F.6/DFS/MS/GH/2021/SZ/ 1017

Dated: 20/12/2021

To

The Addl. Commissioner of Police (Lic.),
1st Floor, P.S. Defence Colony,
New Delhi-110049.

Sub: Issuance of NOC in r/o M/s Hotel Classic Diplomat, A-4, Mahipal pur Delhi 110037


Sir,

This is in reference with MHA Portal ID 2021100623478 Dated 18/10/2021 on the subject cited above. In this connection, the premises have been inspected by officer concerned of this department on 06/12/2021 in the presence of Mr. Arvind Sharma of the Guest House. During the inspection, it was observed that the Guest House is running in 02 Basement, Ground plus Three Upper Floors (4th Floor other property). During the course of inspection, the following shortcoming observed were noticed:-

1. Fire check door is not provided in the building as per clause 7.31 of UBBL-2016.
2. Ventilation system found provided but not functional in basement.
3. Carbon Monoxide detector is not provided as per clause 7.31 of UBBL-2016.

In view of above Shortcomings, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier. The Licensing authority/ Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,



(SUNIL CHAWDHARY)
DY. CHIEF FIRE OFFICER (SZ)

Copy to:-

1. M/s Hotel Classic Diplomat, A-4, Mahipal pur Delhi 110037