

250

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001**

NO. F-6/DFS/MS/2021/SZ/ 1018

Dated 20/12/2021

To

The Joint Commissioner of Police / Lic.  
1<sup>st</sup> floor, Police Station  
Defence Colony, New Delhi.

Sub: - Regarding issuance of fire safety certificate in r/o M/s Hotel Ramhan situated at A-125, N.H- 8, Mahipalpur, New Delhi-110037.


Sir,

This has reference to your MHA Portal ID 2021101924538 Dated: 19.10.2021 on the subject cited above. In this connection this is to inform you that the above mentioned premise was visited by the officer concerned of this department on 06.12.2021 in the presence of Sh. Rohit Kumar, Manager to verify the fire safety arrangements as stipulated in NBC Part 4 and as well installed in the building. Fire Safety Certificate issued vide letter no.1205 dated 06.06.2019 for basement, ground and three upper floors. Your request for FSC is rejected under Rule 37 (3) due to following shortcomings.

- 1 Fire check doors not provided in the building as per clause 7.31 of UBBL 2016.
- 2 Carbon Monoxide detector not provided as per clause 7.31 of UBBL 2016.

In view of above Shortcomings, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier. The Licensing authority/ Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully



**(SUNIL CHAWDHARY)**  
**DY. CHIEF FIRE OFFICER**

Copy to:

1. M/s Hotel Ramhan situated at A-125, N.H- 8, Mahipalpur, New Delhi-110037.