

e-9

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

No. F6/DFS/MS/School/2021/NDZ/ 660

Dated: 16/12/2021

To,
The Principal,
Nagar Nigam Prathmic Adrash Vidyalaya,
Khurezi I & II, Shahdara South,
Delhi-110051

Subject:- Regarding issuance of Fire Safety Certificate.

Sir,

With reference to your letter no. E.E. (Elect.)-II/Shah(S)/2021-2022/D-570 dated 27/10/2021 on the subject cited above, it is informed that officer concerned of this department inspected the school from fire safety point of view in presence of Ms. Puspa Devi, Incharge & Sh. Kuldeep Kumar Singh, J.E (Electric), Shahdara South Zone on dated 25/11/2021. The school building comprises of ground plus three upper floors. During the course of inspection following shortcoming was observed.

1. One additional staircase is not provided in the school building.

In view of the above, the school building cannot be considered for issuance of Fire Safety Certificate at this stage. Therefore, you are requested to rectify the above mentioned fire safety arrangements under intimation to this office for further necessary action.

Yours faithfully,


(Azul Garg)
Director

Copy to:-

The Director of Education, EDMC
Udyog Sadan, Plot No. 419, FIE,
Patparganj, Delhi -92