

C17

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE: CANNAUGHT PLACE  
NEW DELHI- 110001

No. F6/DFS/MS/EH/2021/SZ/ 572

Dated: 15/12/2021

To,

The Joint Commissioner (Lic.)  
1<sup>st</sup> Floor Police Defence Colony,  
New Delhi.

**Sub:** -Regarding issue of "Fire Safety Certificate" from fire safety point of view in r/o M/s SKY ROZO Restaurant/eating house at B-1/625 Third floor, Najafgarh road Janakpuri, New Delhi-110058.

Sir,

Please refer to your letter ID No. ID No. 2021092021965 dated 01/11/2021 on the subject cited above. In this connection this is to inform you that officer concerned of this department inspected the building to verify the fire safety arrangements in accordance with the rules. At the time of inspection Sh. Rohit Arora (Manager) was present and it was observed that the building is comprised of basement, stilt, ground floor plus three upper floors but restaurant is running at third floor and have following shortcomings:-

1. One staircase of 1.25 m is provided instead of 1.5 m wide each of two staircases.
2. Main Fire & Standby pump having 2280 LPM output at 60 m head and jockey pump having 180 lpm not provided.
3. Under ground water storage tank capacity of 1,00,000 liters have not been provided.
4. Exits signage's are not Provided.

In view of above shortcomings, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk & liability of the owner/occupier. The Licensing Authority/Statutory Authority may be take suitable necessary action as deemed fit.

Yours faithfully



(Atul Gang)  
Director

Delhi Fire Service

o/c

Copy to:-

Sh. Rohit Arora (Manager)  
M/s SKY ROZO Restaurant at B-1/625 Third floor,  
Najafgarh road Janakpuri, New Delhi-110058.