

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001**

No. F6/DFS/MS/WZ/2021/School/ 78  
To,

Dated: 17/02/2021

The Principal,  
Bal Bharati Public School,  
Sector-14, Rohini,  
Delhi-110085.

**Sub:** Renewal of Fire Safety Certificate in r/o Bal Bharati Public School, Sector-14, Rohini, Delhi-110085.

Sir,

Kindly reference to online mail dated 25.11.2020, received in this department on the subject cited above. The premise was inspected by the concern nominated authority of this department in presence of 04.02.2021 on Smt. Geeta Gangwani (Principal) to verify the compliance of fire prevention and fire safety measures required under the rules. The renewal of FSC is rejected under sub rule (3) of Rule 37, in the view of reasons mentioned below:

1. One staircase found removed from third floor.

In this regard as stipulated in sub Rule (1) of Rule 37 of DFS Act-2007 & Rules 2010 you are advised to apply again in Form "J" along with a declaration from owner/occupier on Form "K" as required under Rule 38 that all the fire prevention and fire safety measures provided in the building/premise are in best repairs. The web links for DFS Act-2007/ Rules 2010 & Form "J" & "K" are as under:

[http://www.delhi.gov.in/wps/wcm/connect/doi\\_t\\_fire/FIRE/Home/Fire+Safety+Acts+and+Rules/](http://www.delhi.gov.in/wps/wcm/connect/doi_t_fire/FIRE/Home/Fire+Safety+Acts+and+Rules/)  
[http://www.delhi.gov.in/wps/wcm/connect/doi\\_t\\_fire/FIRE/Home/Forms](http://www.delhi.gov.in/wps/wcm/connect/doi_t_fire/FIRE/Home/Forms)

Yours Faithfully

(Dhrampal Bhardwaj)  
Dy.Chief Fire Officer  
Tel;-01123414250

o/c  
my