

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE:**  
**NEW DELHI - 110001**

No.F6/DFS/MS/School/MN/2021/82

Dated: 7/02/2021

To,  
Ms. Anjana Dixit, (Principal)  
Nav Jeewan Model School,  
WZ-IIIA/116, Vishnu Garden,  
New Delhi-110018,

**Subject: Inspection report in respect of Nav Jeewan Model School, Located at WZ-IIIA/116, Vishnu Garden, New Delhi-110018.**

Sir,  
This is reference to your letter no. NJMS/873 dated 19.11.2021 on the subject cited above. In this connection it is to inform you that the premise was inspected by the officer concerned on 13/01/2021 in the presence of Sh. Sandeep Dixit (Owner) to check the shortcomings already pointed out by this deptt. Vide letter no. F6/DFS/MS/2020/712 dated 02/11/2020. During inspection it has been observed that the building is comprised of ground plus three upper floors served by two stair cases having width 77cm & 80 cm. The status of shortcomings is as under:-

Sno.	Shortcomings	Status
1.	Hose reel Hose at each floor are not provided.	Not Rectified
2.	Internal Hydrant at each floor not provided.	Not Rectified
3.	A main Fire Pump of 220 Liter/Minute & a jockey Pump of 180 Liter/minute capacity are not provided.	Not Rectified
4.	Over Head Tank of 2,500 ltr capacity not provided.	Not Rectified

In addition to that following short comings were observed :-

1. Two Staircase widths of 77cm & 80 cm instead of 1 m clear width required.
2. Width of Corridor is 75 cm instead of 1 m clear width required.
3. Door size is 82 cm instead of 1 m clear width required.
4. Exit signage's not provided.

In view of the above shortcomings FSC cannot be considered at this stage. You are requested to comply the above mentioned shortcomings under intimation to this department for further necessary action.

Yours faithfully,

(Atul Garg)  
Director

do 8/2

Copy to:-

1. The Dy. Secretary Home-III, 5<sup>th</sup> level, C-Wing, Delhi Secretariat, IP State, New Delhi-110002.
2. Director of Education, Old Secretariat, Civil Lines, Delhi-110054.
3. Ms. Anjana Dixit, Nav Jeewan Model School, Located at WZ-IIIA/116, Vishnu Garden, New Delhi-110018.