

461

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

No.F6/DFS/MS/School/2021/ 80

Dated 17/02/2021

To,
The Principal,
Shhibban Modern Secondary School,
Vijay Colony, New Usmanpur,
Delhi-53.

Sub:- Request for issuing a Fire Safety Certificate.

Sir,

With reference to your letter No. Ref.No. Smsps/2020/338 dated 24/11/2020 & letter No. F/6/DFS/MS/School/2020/NDZ/611 dated 04/09/2020 issued by this department on the subject cited above, it is informed that officer concerned of this department inspected the school from fire safety point of view on dated 14/01/2021. The School building comprises of ground plus two upper floors. During the course of inspection following observation was made:-

1. The premises is not accessible to fire engines.

In view of the above, the school building cannot be considered for issuance of Fire Safety Certificate at this stage.

Yours Faithfully,


4/2/21

(Dr. S. K. Tomar)
Dy. Chief Fire Officer

Copy to:-

The Joint Director of Education,
(land & Estate)
Director of Education,
Lacknow road, Delhi-54

