

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001

No F.6/DFS/MS/SZ/2021/56

Dated: 05/02/2021

To

The Executive Engineer (Bldg),
South Delhi Municipal Council,
Building Department, South Zone,
Aurobindo Marg, Green Park,
New Delhi-110016

Sub: **Regarding Completion-cum-Occupancy Certificate in r/o Online Building Plan Request ID: 10083013 dated 19/01/2021**


Sir/Madam,

This is with reference to the subject cited above. In this regard, the inspection of the premise was carried out by the officers concerned of this department from fire safety point of view on 02/02/2021 to verify the availability & operability of fire prevention and fire safety measures required under the rules. Sh. Vijay Meena, JE/SDMC and Sh. Anil Kumar Jain (Manager) from building side were present. During the inspection, following shortcomings were observed:

1. Three staircases are provided in basement against required four nos.
2. The sprinkler system shall be extended in enclosed ramp in basement.
3. Fire Check Doors (FCD's) found removed at some places.
4. The smoke management system found provided but non-functional.
5. The required automatic fire detection system not provided on upper floors.
6. The MCP's found removed at some places and non-functional.
7. The fire pumps provided were not on auto mode.
8. The exit signage found removed at some places.

In view of above shortcomings, clearance from fire safety point of view cannot be considered in the interest of public safety.

Yours faithfully,


(Atul Garg)
Director

Delhi Fire Service

908

Copy to: -

1. The Principal, The Mother's International School, Aurobindo Marg, New Delhi-110016