

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS, DELHI FIRE SERVICE, CONNAUGHT PLACE  
NEW DELHI

NO. F6/DFS/MS/School/SZ/2021/102

DATED: 24/02/2021

To,

Smt. Kanta Rani (Principal)  
Akshay Public School,  
Kh, No. 186/2, Sector-16B,  
Dwarka, Kakrola,  
New Delhi-110043

Subject: - Renewal of Fire safety Certificate from fire safety & means of escape point of view in r/o Akshay Public School, Located at, Kh, No. 186/2, Sector-16B, Dwarka, Kakrola, New Delhi-110043.


Sir,

Please refer to your letter no. Email Dated-08/01/2021 on the subject mentioned above. In this connection it is to inform you that the inspection of the premises was carried out by officer concerned of this department on 29/01/2021 for the renewal of fire safety certificate. During course of inspection the following shortcomings were observed:

1. Required fire extinguishers are not provided. Two fire extinguishers of DCP type/CO2 type 2.5Kg Capacity each are required to be provided.
2. First aid hose reel system is not provided.
3. Fire pump of 450 LPM capacity is not provided.
4. Overhead water storage tank of 10000 ltrs, capacity is not provided.
5. Exit signs are not provided.

In view of the above shortcomings Fire Safety Certificate cannot be considered at this stage. You are requested to comply the abovementioned shortcomings under intimation to this department.

Yours faithfully,



(Sunil Chaudhary)  
Dy. Chief Fire Officer,  
Delhi Fire Service

Copy to:

1. Directorate of Education Old Secretariat Delhi – 110054

1/20/21  
20/2/21