

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS, DELHI FIRE SERVICE, CONNAUGHT PLACE  
NEW DELHI

No. F6/DFS/MS/SZ/2021 / 103

Dated: 24/02/2021

To,

The Principal,  
Govt. Girls Senior Secondary School,  
Baprola, New Delhi – 110043.

Subject: Renewal of Fire Safety Certificate iro Govt. Girls Senior Secondary School,  
Located at Baprola, New Delhi – 110043.

Sir,

Please refer to your letter no. GGSSS/SCH/BAP/64 dated 30/01/2021 on the subject mentioned above. In this connection it is to inform you that the premises was inspected by the officer concerned from this department on 11/02/2021 in presence of Sh. T.S Singh (Estate Manager) for fire safety point of view.

1. Passage lead to new block is blocked by parking shed.
2. Some class room doors are found open outward direction, in common passage which is reducing the required width of corridor these shall be re – arranged.
3. Hose Reel Hose found non functional.
4. The pumps found non functional.

You are requested to comply the abovementioned shortcomings under intimation to this department.

In view of the above shortcomings Fire Safety Certificate cannot be considered at this stage.

Yours faithfully,

(Sunil Chaudhary)  
Dy. Chief Fire officer  
Delhi Fire Service

Copy to:-

1. Directorate of Education Old Secretariat Delhi – 110054

10.01  
20/2/21