

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI- 110001**

No. F.6/DFS/MS/School/2021/SZ/ 95

Dated: 23/02/2021

To

The HOS / Vice Principal,
Kendriya Vidyalaya,
Masjid Moth, Sadiq Nagar,
Sector 3, New Delhi 110049

Sub: Reg. renewal of Fire Safety Certificate in r/o Kendriya Vidyalaya, Masjid Moth, Sadiq Nagar,
Sector 3, New Delhi 110049


Sir,

This is in reference with your F. NO: - KV/M.M/2020-21/213 Dated 02/02/2021 on the subject cited above. In this regard, school premises have been inspected by officer concerned of this department on dated 18.01.2021 in presence of Mrs. Poonam Shah (Vice-Principal) to verify the status of existing fire prevention and fire safety measures. During the course of inspection, the shortcomings observed are as below;

1. Fire Extinguishers non functional.
2. Hose reel found non-functional.
3. Terrace pumps found non-functional.

In view of above shortcomings, renewal of Fire Safety Certificate cannot be considered at this stage. You are requested to rectify the shortcoming under intimation to this department for further action in the matter.

Yours faithfully,



(Sunil Chawdhary)
Dy. Chief Fire Officer (SZ)
Delhi Fire Service

Copy to: -

1. The Director of Education, Govt. of NCT of Delhi, Old Secretariat

