

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI – 110001**

NO. F6/DFS/MS/CGHS/SZ/2021/ 104

DATED: 24/02/2021

To,

Ms Radha Ghai (President)
Neo Great Mission Public School,
Sector - 5 Dwarka,
New Delhi - 10075.

Subject: - Renewal of Fire safety Certificate from fire safety & means of escape point of view in r/o the Neo Great Mission Public School, Sector - 5 Dwarka, New Delhi - 75.

Sir,

Please refer to your letter no Email Dated 27-01-2021 on the subject cited above. In this connection it is to inform to you that the above said building has been inspected by the officer concerned of this department on 09/02/2021.

During the course of inspection followings shortcoming have been observed:-

1. The Terrace pump found non functional.
2. Hose reel Hoses found nonfunctional.
3. Overhead water storage tank of 5000 litres capacity found provided against required 10000 ltrs capacity. The tank must be exclusively for fire fighting.
4. The passage/ Exits are found partially blocked. The passages/ Exits must be clear & free from lock & key.
5. Temporary rooms are found erected in the premises.

In view of the above, fire safety certificate cannot be renewed. You are advised to rectify the said shortcomings under intimation to this department for taking further necessary action.

Yours faithfully,



Sunil Chaudhary
(Dy. Chief Fire Officer)
Delhi Fire Service

Copy to:-

1. Director of Education, Govt. of NCT of Delhi, Old Secretariat, New Delhi-110054

10/18/21