

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

No. F6/DFS/MS/2022/NDZ/ 695

Dated: 28 / 03 / 2022

To

Dr. Sushil Kumar
(Medical Superintendent)
Jag Pravesh Chandra Hospital,
Shastri Park, East Delhi-110053.

Sub.:- Fire Safety Certificate in r/o M/s Jag Pravesh Chandra Hospital, Shastri Park, East Delhi-110053.

Sir,

With reference to your letter No. F.NO. 16(1)/H&FW/JPCH/PWD/2020/1228 Dated 04/02/2022 on the subject noted above, in this connection it is to inform you that the said building premises was inspected by the officer concerned of this department on 21/03/2022 in the presence of Sh. Sudhir Kishor, J.E.(E).

Following shortcomings were observed during the time of inspection:-

1. Fire Check Doors Provided but found nonfunctional / Broken & handles defective.
2. Sealing of electric shaft not provided at some places.
3. Smoke managements system provided but non functional.
4. Hose Reel Hose provided but nonfunctional & nozzle found missing at some places.
5. Internal Hydrant & Yard Hydrant hose box found broken at some places an nozzles missing.
6. Fire Pumps not on auto mode.
7. Exit signage found removed.
8. Pressurization of Lift Shaft & Lift Lobby provided but non functional.

In view of above shortcomings, the application for issuance Fire Safety Certificate is rejected under sub rule (3) of rule 35 of DFS Act 2007 and Rules 2010. The occupancy of the building / premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner / occupier. you are requested to apply after rectification of above mentioned shortcomings under intimation to this department.

Yours faithfully,


(ATUL GARG)
DIRECTOR.