



**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001**

e15

No. F6/DFS/MS/EH/WZ/2022/ 276

Dated: 31/03/2022

To

The Joint Commissioner of Police (Lic.),  
1<sup>st</sup> Floor, Police Station Defence Colony,  
New Delhi.

Sub.: - Inspection report for issuance of Fire Safety Certificate in r/o M/s. Kaleva Foods located at WZ-4205, GF-FF, Kh. No. 354, Sant Nagar, Shakurbasti, Rani Bagh, Pitampura, New Delhi- 110034.

Sir,

Please refer to the online application No. 2022021802375 received through MHA portal, on the subject cited above. In this connection, it is to inform you that the aforesaid restaurant has been inspected by the officer concerned of this department, in presence of Sh. Chittaranjan (manager) on 16.03.2022 to check the fire safety arrangements provided in the premises.

During inspection, it has been observed that the said restaurant is running on ground & first floor of a building comprised of ground & first floor. First floor is served by three staircases having width 2.0 mts, 1.5 mts & 0.99 mt. No fire safety arrangement found provided except few fire extinguishers. The following fire safety arrangements are required: -

1. Overhead water storage tank capacity 20,000 lts is required.
2. Terrace pump capacity 450 LPM is required.
3. MOEFA at each floor is required.
4. First aid hose reel hose having 30 mts length with shut off nozzle & down comer with two nos. of delivery hoses and one branch pipe are required at each floor.
5. Exit signages are required at the places mentioned during inspection.
6. Standby power supply is required.

In view of the above shortcomings, the application for grant of Fire Safety Certificate is rejected. The occupancy of the building / premises in absence of requisite Fire safety arrangements shall be at the risk and liability of the owner/occupier. The licensing authority /statutory authority may take suitable necessary action as deemed fit.

Yours faithfully

(Atul Garg)  
Director

Copy to: -

1. The Deputy Health Officer, North Delhi Municipal Corporation, Keshavpuram Zone, New Delhi.
2. Sh. Naman Aggarwal, Owner/occupier, M/s. Kaleva Foods, WZ-4205, GF-FF, Kh. No. 354, Sant Nagar, Shakurbasti, Rani Bagh, Pitampura, New Delhi- 110034.

27