

## GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI HEADQUARTERS, DELHI FIRE SERVICE, NEW DELHI-110001

Cyl

No. F6/DFS/MS/WZ/2022/EH 273

Dated: 29 / 03 /2022

The Joint Commissioner of Police, Licensing Unit, 1<sup>st</sup> floor, Police Station, Defence Colony, New Delhi. addlep.lic-dl@nic.in

## Sub: - <u>Inspection report in r/o M/S Lee Pacific Restaurant at 31/35 F.F & S.F, Rohtak</u> Road, West Punjabi Bagh, New Delhi.

Sir.

Please refer to your online application ID no. 2022022002421 dated 19/02/2022 on the subject cited above. In this connection, it is to inform you that the said building was re inspected by the officers concerned of this department on 11/03/2022 in presence of Sh. Sanjay Bansal to check the shortcomings already issued by this department vide letter no. F6/DFS/MS/EH/WZ/2021/541 dated 30/11/2022.

The Status of the Shortcomings are as under.

S.	Shortcomings	Status
no.		
1.	Width of staircase 1.5 mts & 1.2 mts are provided against	Not Rectified
	requirement of 1.5 mts. each.	
2.	Door size 104 cms & 181 cms are provided against	Not Rectified
	requirement of 1.5 mts each.	
3.		Rectified
4.	1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1	Not Rectified
5	Main Fire Pump of 2280 lpm is not on auto mode & stand	Not Rectified
]	by pump of Same Capacity is found removed.	
6.	Exit signage's are found removed	Not Rectified

In view of above Shortcomings the application for Issuance of Fire safety Certificate is rejected. The occupancy of the Building/ premises in absence of requisites fire safety Arrangements Shall be at the risk and liabilities of the Owner/occupier. The licensing issuing authority/statutory authority is requested that premises should not be allowed to run till it provide all necessary fire arrangements.

Yours Faithfully

(Dharampal Bhardwaj)
Dy. Chief Fire Officer
West Zone

Copy To: -

1. The Owner/Occupier M/s. Playgue club & lounge C-7, First floor located at Vishal Enclave, Rajouri garden, New Delhi-110027.

2. The Dy. Health Officer, SDMC, West Zone, Vishal Enclave, Rajouri Garden, New Delhi 110027. (dhowest zone@gmail.com).

3. The Joint Commissioner of Police, Licensing Unit, 1<sup>st</sup> floor, Police Station, Defence Colony, New Delhi.addlcp.lic-dl@nic.in