

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI – 110001

No. F6/DFS/MS/WZ/2022

200/704

Dated: 29/03/2022

To,

The Authorized Signatory,
M2K Entertainment Pvt Ltd.,
Plot no. 4, Road no. 44, Community Centre,
Pitampura, New Delhi.

Sub.: - Inspection from fire safety point of view in r/o M2K Entertainment Pvt Ltd. Located at Plot no. 4, Road no. 44, Community Centre, Pitampura, New Delhi.

Sir,

This has reference to your letter no.nil dated 16.02.2022 on the subject cited above. In this connection it is to inform you that the above said cinema hall was inspected by the officer concerned of this department from fire safety point of view on 14.03.2022 in the presence of Sh. Sanjay (Manager) to check the shortcomings issued by this department vide letter no. F6/DFS/MS/WZ/2021/Cinema/2526 dated 03.12.2021.

During the course of inspection it has been observed that the Management has rectified some of the shortcomings, the status is as under:-

S. no.	Shortcomings	Status
1.	Ventilation system is not functioning properly.	Still not rectified
2.	Exhaust fan is removed from projection room. One hooter is required in projector room.	Rectified

In view of the above shortcomings, the application for issuance of Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier. The Licensing Authority/Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,

(Dharampal Bhardwaj)
Dy. Chief Fire Officer

West Zone)

Copy to:-

1. The SDM, DDMA, HQ, District North West, Kanjhawala, Delhi