

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

NO.F6/DFS/MS/Hospital/2022/WZ/ 547

Date:

10/03/2022

To,

The Medical Superintendent,
Maharishi Valmiki Hospital,
Pooth Khurd, Delhi-110039.

Sub: Regarding present status of fire clearance of Maharishi Valmiki Hospital, Pooth Khurd, Delhi-110039.

Sir,

This has the reference to the directions issued by GNCT of Delhi for inspection of the Govt. Hospitals. In this regard, it is submitted that the aforesaid hospital building was re-inspected by officers concerned of this department on 22.02.2022 in presence of Sh. Md. Imran, J.E.(electrical) and observed that shortcomings issued vide this department letter No. F.6/DFS/MS/Hospital/2021/WZ/2766 dated 28/12/2021 are not yet rectified completely and grant of FSC for New building & renewal of Old building is rejected under sub rule (4) of Rule 35. Till such time, occupancy of hospital building is at your risk. The status of shortcoming is as under.

New Building:

1. Width of internal road is 5.8 meters against required 6.0 meters due to 20mm gap façade on surface of the building.
2. FCD required in refuge area at 6th floor.
3. Floor landing signage's not provided.
4. FCD required in AHU room.
5. Staircases are not segregated from ground to upper floors.
6. Compartmentation of the building is found affected by common ducting of passing vertically and horizontally without dampers.

Old Building;

1. Changes in building as per approved building plans for addition/alteration vide this department guidelines letter of even no. 204 dated 24.08.2016 not found carried out as only single staircase is going up to terrace level/lift lobbies not found provided.