

214



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE : NEW DELHI – 110001

No. F6/DFS/MS/School/2022/ 147

Dated 29/03/2022

To,

The Principal
Nigam Pratibha Vidyalaya
Adarsh Nagar-1, Delhi-110033.

Sub: - Regarding issuance of fire safety certificate in r/o Nigam Pratibha Vidyalaya located at Adarsh Nagar-1, Delhi-110033.

Sir,

This has reference to your letter no. Nil dated 21.02.2022 on the subject cited above. In this connection this is to inform you that the above mentioned site was visited by the officer concerned of this department on 14.03.2022 in presence of Smt. Neelam Aneja (Principal) and verify the compliance of the shortcomings/ observations already communicated by this department vide letter of even no. 43 dated 07.01.2015 and observed that the shortcomings have not been removed so far.

Keeping in view of above, Fire Safety Certificate cannot be considered at this stage.

Yours faithfully,


(Atul Garg)
Director

Ph: 011-23414250



Copy to:-

1. The Director, Education, Government of N.C.T of Delhi. Old Sectt. Delhi – 110054.

c-7

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

NO. F-6/DFS/MS/2014 *school/43*

Date: *07/01/2014*

To

The Dy. Director of Education,
NDMC Civil Line Zone,
5th floor Rajpur Road,
New Delhi 54,

Sub: -Regarding fire safety certificate in respect of M C Primary Model Boys School-Adarsh Nagar-II, Delhi-110033.

Sir,

Please refer to your letter No D/5309/DDE/CLZ/2014 dated 07/10/2014 on the subject cited above. In this connection this is to inform you that the inspection of the above said premises was carried out by the officer concerned of this department along with school authority on 14/11/2014 from fire safety point of view and the following shortcomings were observed.

1. Three fire extinguishers of ABC type provided against the required 15 no's of ABC / Co2 type. 12 more fire extinguishers ABC / Co2 type shall be provided.
2. First-aid hose reel not provided.
3. Discharge Pump capacity of 450 LPM with 40 m head not provided.
4. Overhead tank capacity of 10,000 ltr not provided.
5. Exit Signage Not provided.

In view of the above fire safety certificate cannot be considered at this stage. You are requested to provide the fire safety arrangements as per the NBC Part IV.

Yours faithfully

W
STI
(VIPIN KENTAL)
Dy. Chief Fire Officer
Ph: 011-23846352

Copy To:

1. The Principal, M C Primary Model Boys School-Adarsh Nagar-II, Delhi-110033